

**From:** Robert Derricott [<mailto:Robert.Derricott@bovishomes.co.uk>]  
**Sent:** 22 October 2018 15:05  
**To:** Deborah Smith  
**Cc:** Rob Stroud; [lee.griffin@lindenhomes.co.uk](mailto:lee.griffin@lindenhomes.co.uk); Guy Wakefield  
**Subject:** RE: Meeting

Deborah

Further to my email of Friday, I would like to provide a further update with respect to the COMAH Regulations (item 5).

The COMAH Regulations with specific regard to LPG apply where an installation exceeds 50 tonnes in quantity. I have now received confirmation from Calor relating to their installation at Upper Rissington, confirming that the maximum capacity is 48 tonnes (4no. 12T vessels).

Hi Rob,

Further to our conversation today, I can confirm that the vessels that we have installed at the Upper Rissington estate are each of a capacity of 12 tonnes. The total capacity of the storage at the site is 48 tonnes.

COMAH regulations apply to sites with 50 tonnes or more of storage capacity for LPG.

Kind Regards

Toby

Toby Harris  
Safety and Compliance Manager  
Calor Gas Ltd.

I would also note that the installation is not part of the Bovis Homes / Linden Homes development. It is therefore not necessary to seek an approval under the COMAH Regulations.

Hopefully this is sufficient to conclude this particular aspect of the questions raised.

Regards  
Rob