

From: Helen Ramsell
Sent: 09 April 2019 18:16
To: Sophie Browne
Subject: RE: Ref 18/04606/COMPLY - The Watchtower Little Rissington GL 54 2QB

Hi Sophie,

I have looked through the additional details and can confirm the following:

Render sample – this is acceptable. I have read the information regarding the textured finish and seen the indicative photograph and am of the view that this is fine in terms of colour and texture.

Windows – now that the glazing bar detail has been provided I can confirm that these are acceptable

Doors – these are acceptable

Porch – acceptable

Garage doors – these are acceptable now that we can see which specific product is proposed with the further information provided including the brochure

Glazed link – sorry I couldn't find the drawing the architect referred to in his email of the 2/04/19 showing the further details of the eaves etc – 1097-39-B. If you can forward this to me via one of the emails received I can check the detail and confirm.

I am on leave from today but will check my emails at home on Thursday for the additional drawing so I can respond then so that we can release this one asap.

Thanks,

Helen

(Please note: I work Tuesdays, Thursdays and Fridays only)

Helen Ramsell BA (Hons), MSc, IHBC
Senior Conservation & Design Officer

Heritage and Design Service
Cotswold District Council
www.cotswold.gov.uk
Tel. 01285 623000