

From: Katie Smith
Sent: 09 May 2019 14:18
To: Sophie Browne
Subject: RE: Ref 18/04606/COMPLY The Watchtower, Upper Rissington

Hi Sophie

Re. The Watchtower, Upper Rissington – ref. 18/04606/ COMPLY

Condition 6 (landscaping scheme)

The submitted Site Plan (1097-12 Rev. E) does not address my previous comments below.


Comments on 13th March:- *“Thank you for your email. For clarity can you kindly confirm that the purple lines (shown on the plan below) would be Beech hedging and the remaining blue lines would be mixed native hedging? If this is correct I can confirm that I would have no objection to this. I can also confirm that I would be supportive of a planting density of 5 plants per linear m”.*



The fencing should be clearly labelled on this plan. A picket fence left to silver would be acceptable along the northern boundary (frontage) and a post and wire fence to the eastern boundary.

Details of Entrance Gates and Picket Fence (1097-53 Rev.-)

- The steel gates and pillars detail is acceptable.
- Picket fencing along the frontage would be acceptable, but this should be left untreated to silver so that it blends in with the surroundings. I would suggest that the eastern boundary is enclosed by a timber post and wire fence (see below).



To discharge condition 6 further updates are required.

Many thanks
Katie

Landscape Officer (Mon-Thurs)

Cotswold District Council